



LAKE SUPERIOR STATE UNIVERSITY

Environmental Analysis Laboratory

Date: June 7, 2018

To: City of Stayton
362 N 3rd
Stayton, OR, 973831726

From: Mr. Benjamin Southwell, Environmental Laboratory Manager and Chemist, LSSU

Subject: Data Report for Cyanotoxin Samples Supplied 6/5/18

Summary: Listed below are the results for the analysis of the supplied samples. An enzyme linked immunosorbent assay (ELISA) was utilized for the analysis of Cylindrospermopsin and Microcystin.

Sample Identification:	Collection Date	Cylindrospermopsin (µg/L)	Microcystin (µg/L)
Raw	6/1/18	<0.05	<0.15
Finished	6/1/18	<0.05	<0.15
Assay Limit of Detection		0.05	0.15

650 W. Easterday Ave., Sault Ste. Marie, MI 49783

Telephone: 906-635-2076 • Fax: 906-635-2266

www.lssu.edu